Very Turbid
Yellow color

Boulder Office
3450 Broadway
Phone 441-3585

STANDARD BACTERIOLOGICAL WATER TEST

Boulder City-County Health Department

Longmont Office
525 4th Ave.
Phone 776-5743

Sample taken: Date 4/23/76 Name of Supply Allied Chem County Bld

Type of Supply:
( ) Private
( ) Municipal Semi
( ) Food Establishment

Source:
(✓) Well
( ) Surface
( ) Raw Water

Time 9:00
Temperature
pH 7.2
Chlorine Residual 0.0 mg/l

Sample Taken by: Gray

Legal Description:

Fill in all Information

Return Report to: Allied Chemical

Address 63rd & Valmont

City-State

SEE REVERSE SIDE FOR SAMPLING INSTRUCTIONS

LAB-MICRO 5000 1975 ESTEY

RESULTS

		Coliform per 100 ml
MF	0	
LB		48
BGB		48
SPC		
MPN		

SAMPLE IS:
☑ SAFE
☐ UNSAFE
☐ UNSATISFACTORY FOR TEST
Please re-submit

Date Tested 9/6/76

Specimen Identification Number 9377

Semi-public

Boulder Office
3450 Broadway
Phone 441-3585

STANDARD BACTERIOLOGICAL WATER TEST

Boulder City-County Health Department

Longmont Office
525 4th Ave.
Phone 776-5743

Sample taken: Date 11/9/77 Name of Supply Hendricks County Bld

Type of Supply:
( ) Private
(✓) Municipal
( ) Food Establishment

Source:
(✓) Well
( ) Surface
( ) Raw Water

Time 3:25
Temperature
pH 7.4
Chlorine Residual 0.0 mg/l

Sample Taken by: J. Watkins

Legal Description: 3000 N. 63rd St, Bathroom Tap

Fill in all Information

Return Report to: Hendricks Mining

Address 3000 N. 63rd St

City-State Boulder, Co

SEE REVERSE SIDE FOR SAMPLING INSTRUCTIONS

LAB-MICRO 5000 1975 ESTEY

RESULTS

		Coliform per 100 ml
MF	0	
LB	24	48
BGB	24	48
SPC		
MPN		

SAMPLE IS:
☑ SAFE
☐ UNSAFE
☐ UNSATISFACTORY FOR TEST
Please re-submit

Date Tested 11/11/77

Specimen Identification Number 7063