

BOULDER CITY-COUNTY HEALTH DEPARTMENT  
3450 BROADWAY  
BOULDER, COLORADO 80302

TO: Allied Chemical, 63rd & Valmont Drive, Boulder, Co.  
FROM: Rod Gardner, R.P.S.  
Water Quality Control Coordinator, Division of Environmental Health  
SUBJECT: Disinfection of Public Water Supplies  
DATE: April 26, 1976

---

Section 9 of the Colorado Department of Health Regulations captioned, "Quality of Water Supplied the Public", adopted February 12, 1962, effective March 15, 1962, amended October 17, 1967, reads:

9. Disinfection of Drinking Water -- All drinking water supplied to the public shall be disinfected by chlorination or other means or methods of equal efficacy in the killing or removal of organisms capable of causing infection. When chlorination is employed, a sufficient amount of chlorine shall be added to the water to maintain a measurable chlorine residual at all points in the distribution system from which the water may be withdrawn.

Please note that recent reports of field tests for the chlorine content of the water from your water system have not shown any chlorine present.

According to standards for the "Quality of Water Supplied to the Public" and "Guidelines" by the Colorado Department of Health, this is a public supply, serving two or more people, and therefore the water should be chlorinated.

This is to request that you exercise any or all means at your disposal to insure that the water in the system will be disinfected at all times in the future.

Your complete cooperation will be appreciated.