BOULDER CITY-COUNTY HEALTH DEPARTMENT
WATER QUALITY CONTROL SECTION
3450 Broadway
Boulder, Colorado 80302

WATER SUPPLY INSPECTION FORM

Water Supply: Hedricks Mining Co. Address: 3000 N 63rd

Owners Name: Tusco Address: Phone: 443-1502

Population Served: ~17 Taps: 3-4 Season: Year Round

ITEM	COMMENTS
1. **SOURCE:** a. Drilled ___ Dug ___ Depth ___ Other: Small collection Pond b. Location: West of Milling operation c. Well Head: — Pitless Adapter: — d. Adequate Cover: — Casing: — e. Protection From Flooding/Runoff: NO f. Type and Distance to Pollution Sources: —	Pond water is used for milling process, Lavatories + fire protection. Unsafe water signs posted
2. **PUMP:** a. Type: Centrif. b. Location: Pump house beside pond	
3. **STORAGE:** a. Pressure ___ Gravity: ✓ Other ___ b. Capacity: Unknown c. Location: Hill N. of Mine d. Sanitary Condition: —	
4. **TREATMENT:** a. Sedimentation ___ Coag./Floc. ___ Filters ___ Conditioning/Softening ___ Operation ___	**DEFICIENCIES** You are hereby ordered to correct the following items within ___ days. OK
5. **DISINFECTION:** a. Provided: NO b. Agent ___ c. Method ___ d. Operation ___ e. Detention Time ___ f. Tap Residual ___ g. Test Kit ___	
6. **SAMPLE ANALYSIS:** a. Sample Taken: NO b. MF ___ c. Chemical ___	
7. **PHYSICAL TESTS:** ___	
8. **OTHER POTABLE WATER PROVIDED:** a. yes b. Source: Ever clear Bottled Water	

Date: 1-30-84 Sanitarian: Chuck [illegible] Phone: 441-1196

Person Interviewed: J. Burnett

R.H.